

© Copyright SEK. Reproduction in any form without permission is prohibited.

**Järnvägstillämpningar –
Fasta installationer –
Särskilda fordringar på växelspänningsställverk –
Del 3-2: Mät-, manöver- och skyddsutrustning för
speciell användning i växelspänningstraktionsystem –
Strömtransformatorer**

*Railway applications –
Fixed installations –
Particular requirements for a.c. switchgear –
Part 3-2: Measurement, control and protection devices for
specific use in a.c. traction systems –
Current transformers*

Som svensk standard gäller europastandarden EN 50152-3-2:2016. Den svenska standarden innehåller den officiella engelska språkversionen av EN 50152-3-2:2016.

Nationellt förord

Standarden ska användas tillsammans med SS-EN 61869-1, utgåva 1, 2009 och SS-EN 61869-2, utgåva 1, 2013.

Tidigare fastställd svensk standard SS-EN 50152-3-2, utgåva 1, 2001, gäller ej fr o m 2019-04-25.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English Version

Railway applications - Fixed installations - Particular requirements for a.c. switchgear - Part 3-2: Measurement, control and protection devices for specific use in a.c. traction systems - Current transformers

Applications ferroviaires - Installations fixes - Spécifications particulières pour appareillage à courant alternatif - Partie 3-2: Dispositifs de mesure, de commande et de protection pour usage spécifique dans les systèmes de traction à courant alternatif - Transformateurs de courant

Bahnanwendungen - Ortsfeste Anlagen - Besondere Anforderungen an Wechselstrom-Schaltanlagen - Teil 3-2: Mess-, Steuerungs- und Schutzeinrichtungen für Wechselstrom-Bahnanlagen - Stromwandler

This European Standard was approved by CENELEC on 2016-04-25. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword.....	4
1 Scope	6
2 Normative references	6
3 Terms, definitions and abbreviations	6
3.1 Terms and definitions	6
3.2 Abbreviations	7
4 Service conditions.....	8
5 Rating.....	8
5.1 General	8
5.2 Nominal voltage (U_n)	8
5.3 Rated voltage (U_{Ne})	8
5.4 Insulation coordination	8
5.4.1 General	8
5.4.2 Rated insulation level.....	8
5.5 Rated frequency.....	9
5.6 Rated accuracy classes	9
6 Design and construction	9
6.1 General	9
6.2 Transformer construction.....	9
6.3 Requirements for the external insulation	10
6.4 Electromagnetic compatibility (EMC)	10
6.5 Nameplates.....	10
7 Tests	10
7.1 General	10
7.2 Electromagnetic compatibility tests (EMC)	10
7.3 Partial discharge test	10
8 Rules for transport, storage, erection, operation and maintenance	10
9 Safety	11
10 Influence of the product on the environment	11
11 Information to be given with enquiries, tenders and orders.....	11
Bibliography	12

Tables

Table 1 - Nominal voltages (U_n), rated voltages (U_{Ne}), rated impulse voltages (U_{Ni}) and power-frequency withstand voltage (U_d) for circuits connected to the contact line.....	9
Table 2 – Partial discharge test voltages and permissible levels for current transformers with solid insulation	10

European foreword

This document (EN 50152-3-2:2016) has been prepared by SC 9XC "Electric supply and earthing systems for public transport equipment and ancillary apparatus (Fixed installations)" of CLC/TC 9X "Electrical and electronic applications for railways".

The following dates are fixed:

- latest date by which the existence of (doa) 2016-10-25
this document has to be announced
at national level
- latest date by which this document has to be (dop) 2017-04-25
implemented at national level by publication of
an identical national standard or by
endorsement
- latest date by which the national standards (dow) 2019-04-25
conflicting with this document have to
be withdrawn

This document supersedes EN 50152-3-2:2001.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This standard was revised to reflect the latest versions of standards referenced and to remove text already included in the EN 61869 Series. The structure of the document was adapted to that of EN 50152-1 and EN 50152-2. Ratings have been added to provide designations in line with other railway standards e.g. EN 50124. Tests requirements have been detailed to meet operating conditions of railway applications. Partial discharge voltages have been specified in Table 2.

This standard has to be read in conjunction with EN 61869-1:2009 and EN 61869-2:2012.

Where a particular clause/subclause of EN 61869-2 is not mentioned in this standard, that clause/subclause applies as far as reasonable. Where requirements relate exclusively to three-phase systems or to voltages outside those in use in traction systems, they are not applicable. Where this standard states "addition" or "replacement", the relevant text of EN 61869-2 is to be adapted accordingly.

The numbering of clauses in EN 61869 Series is similar to that in the EN 50152 Series.

Where terms defined in EN 61869-1 and EN 61869-2 conflict with definitions of the same terms as given in IEC 60050-811:1991 or of the other railway applications documents listed in the normative references, the definitions in EN 61869-1 and EN 61869-2 are to be used.

NOTE The suffix N which appears in this standard for rated values is not present in EN 61869-1 and EN 61869-2.

References in subclauses of EN 61869-1 and EN 61869-2 have to be replaced by references to applicable subclauses in this standard as far as reasonably possible.

EN 50152 Series under the generic title "*Railway applications - Fixed installations - Particular requirements for a.c. switchgear*" is divided as follows:

- Part 1: Circuit-breakers with nominal voltage above 1 kV;
- Part 2: Disconnectors, earthing switches and switches with nominal voltage above 1 kV;
- Part 3-1: Measurement, control and protection devices for specific use in a.c. traction systems – Devices;
- Part 3-2: Measurement, control and protection devices for specific use in a.c. traction systems – Current transformers;
- Part 3-3: Measurement, control and protection devices for specific use in a.c. traction systems – Voltage transformers.

1 Scope

This EN 50152-3-2 is applicable to new current transformers which are:

- intended for use in indoor or outdoor fixed installations in traction systems, and
- operated with an a.c. line voltage and frequency as specified in EN 50163.

NOTE 1 EN 50163 specifies the a.c. traction systems 15 kV 16,7 Hz and 25 kV 50 Hz.

NOTE 2 As rails of a.c. traction systems are typically connected to earth and included in the return current path, all phase to earth voltages are subject to the limits as given in EN 50163. Nevertheless conductor to conductor voltages are some times higher e.g. in autotransformer systems.

Current transformers are mainly used with:

- measuring instruments,
- protective devices.

This EN 50152-3-2 also applies to current transformers other than inductive types as far as reasonably possible. Requirements of this EN 50152-3-2 have priority.

NOTE 3 Combined current and voltage transformers are typically not used in fixed installations in traction systems.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50121-5:2006, *Railway applications - Electromagnetic compatibility - Part 5: Emission and immunity of fixed power supply installations and apparatus*

EN 50124-1:2001, *Railway applications - Insulation coordination - Part 1: Basic requirements - Clearances and creepage distances for all electrical and electronic equipment*

EN 50125-2:2002, *Railway applications - Environmental conditions for equipment - Part 2: Fixed electrical installations*

EN 50152 Series, *Railway applications - Fixed installations - Particular requirements for a.c. switchgear*

EN 50163:2004, *Railway applications - Supply voltages of traction systems*

EN 61869-1:2009, *Instrument transformers - Part 1: General requirements (IEC 61869-1:2007, mod.)*

EN 61869-2:2012, *Instrument transformers - Part 2: Additional requirements for current transformers (IEC 61869-2:2012)*