

SVENSK STANDARD SS-EN 62110

FastställdUtgåvaSidaAnsvarig kommitté2010-06-2111 (1+50)SEK TK 106

© Copyright SEK. Reproduction in any form without permission is prohibited.

Elektriska och magnetiska fält från växelströmsnät – Mätning med avseende på allmänhetens exponering

Electric and magnetic field levels generated by AC power systems – Measurement procedures with regard to public exposure

Som svensk standard gäller europastandarden EN 62110:2009. Den svenska standarden innehåller den officiella engelska språkversionen av EN 62110:2009.

Nationellt förord

Europastandarden EN 62110:2009

består av:

- europastandardens ikraftsättningsdokument, utarbetat inom CENELEC
- IEC 62110, First edition, 2009 Electric and magnetic field levels generated by AC power

systems - Measurement procedures with regard to public exposure

utarbetad inom International Electrotechnical Commission, IEC.

ICS 17.220.20; 29.240

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden. Postadress: SEK, Box 1284, 164 29 KISTA *Telefon*: 08 - 444 14 00. *Telefax*: 08 - 444 14 30 *E-post*: sek@elstandard.se. *Internet*: www.elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284 164 29 Kista Tel 08-444 14 00 www.elstandard.se

EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN 62110

December 2009

ICS 17.220.20; 29.240

English version

Electric and magnetic field levels generated by AC power systems -Measurement procedures with regard to public exposure (IEC 62110:2009)

Champs électriques et magnétiques générés par les systèmes d'alimentation à courant alternatif -Procédures de mesure des niveaux d'exposition du public (CEI 62110:2009) Magnetische Felder, die von Wechselstrom-Energieversorgungssystemen erzeugt werden -Messverfahren im Hinblick auf die Exposition der Allgemeinbevölkerung (IEC 62110:2009)

This European Standard was approved by CENELEC on 2009-11-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

© 2009 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

Ref. No. EN 62110:2009 E

Foreword

The text of document 106/177/FDIS, future edition 1 of IEC 62110, prepared by IEC TC 106, Methods for the assessment of electric, magnetic and electromagnetic fields associated with human exposure, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 62110 on 2009-11-01.

The following dates were fixed:

-	latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement	(dop)	2010-08-01
-	latest date by which the national standards conflicting with the EN have to be withdrawn	(dow)	2012-11-01

Terms defined in Clause 3 appear in *italics* throughout the document.

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 62110:2009 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC 61000-2-2 NOTE Harmonized as EN 61000-2-2:2002 (not modified).

EN 62110:2009

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

Publication	Year	Title	<u>EN/HD</u>	<u>Year</u>
IEC 61786	_1)	Measurement of low-frequency magnetic and electric fields with regard to exposure of human beings - Special requirements for instruments and guidance for measurement	-	-

¹⁾ Undated reference.

CON	TEN	١TS
-----	-----	-----

INT	RODL	JCTION	7		
1	Scop	e	8		
2	Normative reference				
3	Term	is and definitions	8		
4	Measurement principle for electric and magnetic fields				
-	4 1	General	g		
	4.2	Instruments	9		
	4.3	Harmonic content	10		
	4.4 Record of measurement result				
	4.5	Measurement considerations	.11		
	-	4.5.1 Field orientation	.11		
		4.5.2 Measurement locations	. 12		
		4.5.3 Perturbing effects of an operator in electric field measurement	. 12		
		4.5.4 Effects from other sources in magnetic field measurement	. 12		
		4.5.5 Humidity condition in electric field measurement	. 12		
5	Fund	amental measurement procedures for electric and magnetic fields	. 12		
	5.1	General procedure	. 12		
	5.2	Single-point measurement	.13		
	5.3	Three-point measurement	.13		
	5.4	Five-point measurement	. 14		
6	Meas	surement procedures for finding the maximum exposure level to an electric			
	field.		. 15		
	6.1	Overhead lines	. 15		
	6.2	Underground cables	. 15		
_	6.3	Substations and power system equipment	. 15		
1	Measurement procedures for finding the maximum exposure level to a magnetic				
	7 1	Overboad lines	16		
	7.1 7.2	Underground cables	10		
	73	Substations and nower system equipment	16		
Δnr		(informative) Characteristics of electric fields generated by AC overhead	. 10		
line	S		. 18		
Anr	nex B	(informative) Characteristics of magnetic fields generated by AC power			
sys	tems.		. 30		
Anr	nex C	(informative) Concept of the three-point measurement with regard to the			
ave	rage e	exposure level	.42		
Anr	nex D	(informative) Example of a reporting form for field measurement	. 47		
Bib	liograp	phy	. 50		
Fig	ure 1 -	– Heights of the three-point measurement	.13		
Fia	ure 2 -	– Five-point measurement	. 14		
Fin	ure A	1 – Linear charge distribution above ground	19		
Fig	ire Δ	2 - General n-phase system with around	20		
Eim		2 Electric field levels under an everband transmission line	. <u>2</u> 0		
Figi	ure A.	5 - LIECUIC HEIN IEVEIS UNDER AH OVERHEAN HANSINISSION IINE	. 22		

Figure A.4 – Electric field levels under an overhead transmission line with bundled conductors	22
Figure A.5 – Electric field levels and non-uniformity under a 77 kV overhead transmission line – Effect of heights of conductors	24
Figure A.6 – Electric field levels and non-uniformity under a 500 kV overhead transmission line – Effects of the heights of conductors	25
Figure A.7 – Electric field levels under a 77 kV overhead transmission line – Effect of separation between conductors	26
Figure A.8 – Electric field levels and non-uniformity under a 500 kV overhead transmission line – Effect of separation between conductors	27
Figure A.9 – Vertical and horizontal components of electric field levels under a 77 kV overhead transmission line	27
Figure A.10 – Vertical and horizontal components of electric field levels under a 500 kV overhead transmission line	28
Figure A.11 – Electric field contour of a 25 kV overhead line	28
Figure A.12 – Electric field profile along the wall of a building and at 1 m above ground level.	29
Figure B.1 – Magnetic field levels under a 77 kV overhead transmission line	32
Figure B.2 – Magnetic field levels under a 500 kV overhead transmission line	33
Figure B.3 – Magnetic field levels and non-uniformity under a 77 kV overhead transmission line – Effect of heights of conductors	34
Figure B.4 – Magnetic field levels and non-uniformity under a 500 kV overhead transmission line – Effect of heights of conductors	35
Figure B.5 – Magnetic field levels and non-uniformity under a 77 kV overhead transmission line – Effect of separation between conductors	36
Figure B.6 – Magnetic field levels under a 500 kV overhead transmission line – Effect of separation between conductors	37
Figure B.7 – Values of semi-major and semi-minor components (r.m.s.) of magnetic field levels under a 77 kV overhead transmission line	38
Figure B.8 – Values of semi-major and semi-minor components (r.m.s.) of magnetic field levels under a 500 kV overhead transmission line	38
Figure B.9 – Magnetic field levels and non-uniformity under an overhead distribution line (6 600 V / 100 V)	39
Figure B.10 – Magnetic field levels and non-uniformity above underground cables – Effect of buried depth	40
Figure B.11 – Magnetic field levels and non-uniformity above underground cables – Effect of separation between conductors	40
Figure B.12 – Measured magnetic field levels and non-uniformity around a 6 600 V pad-mounted transformer	41
Figure B.13 – Measured magnetic field levels and non-uniformity around 6 600 V vertical cables	41
Figure C.1 – A spheroidal human model	42
Figure C.2 – The model in the magnetic field generated by a straight cable	43
Figure C.3 – Magnetic field levels generated by a straight cable	43
Figure C.4 – The model in the magnetic field generated by three parallel cables	44
Figure C.5 – Magnetic field levels generated by three balanced parallel cables	44
Figure C.6 – The model in the magnetic field generated by underground cables	45
Figure C.7 – Magnetic field levels generated by underground cables	45
Figure C.8 – The model in the magnetic field generated by overhead wires	46

Figure	C.9 – Magnetic	field levels generat	ed by balanced	overhead wir	es
i igui o	o.o magnotio	nola lovolo gonolat	oa by baiaiiooa		00

INTRODUCTION

All populations of the world are now exposed to electric and magnetic fields and the levels will continue to increase with developing industry and technology. A number of countries have implemented regulations on public exposure to these fields. Therefore, in order to evaluate human exposure levels to these fields adequately, common measurement procedures are required by not only professionals of national authorities and electric power industries, but also the general public.

This standard is applied to the measurement of fields generated by AC power systems in areas accessible to the public. It establishes a common measurement procedure to evaluate the exposure levels of the human body to electric and magnetic fields among the general public.

The values obtained are for use to determine whether the fields comply with exposure limits by comparing them with the field limits for general public exposure such as the reference levels from the ICNIRP (International Commission on Non-Ionizing Radiation Protection) Guidelines [1]¹, MPE (maximum permissible exposure) from the IEEE (Institute of Electrical and Electronics Engineers) [2] or in national regulations. If the values obtained are higher than the reference level or MPE, it does not necessarily mean that the basic restriction has been exceeded, in which case other methods must be used to ensure that basic restriction is not exceeded.

The values obtained by using the procedures in this standard are for the load conditions occurring at the time of measurement. Therefore, in the case of magnetic field, in order to check compliance with some exposure guidelines or regulations these values may need to be extrapolated to take account of the maximum load of the circuits.

This standard is not applicable to occupational exposure associated with, for example, the operation and/or maintenance of the power systems. Such exposure may occur when working inside a distribution or transmission substation, a power plant, in a manhole or a tunnel for underground cables, or on an overhead line tower or pole.

¹⁾ Numbers in square brackets refers to the Bibliography.

ELECTRIC AND MAGNETIC FIELD LEVELS GENERATED BY AC POWER SYSTEMS – MEASUREMENT PROCEDURES WITH REGARD TO PUBLIC EXPOSURE

1 Scope

This International Standard establishes measurement procedures for electric and magnetic field levels generated by AC power systems to evaluate the exposure levels of the human body to these fields. This standard is not applicable to DC power transmission systems.

This International Standard is applicable to public exposure in the domestic environment and in areas accessible to the public.

This standard specifies fundamental procedures for the measurement of fields, and, with regard to human exposure, for obtaining a field value that corresponds to a spatial average over the entire human body.

This standard is not applicable to occupational exposure associated with, for example, the operation and/or maintenance of the power systems. Such exposure may occur when working inside a distribution or transmission substation, a power plant, in a manhole or a tunnel for underground cables, or on an overhead line tower or pole.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61786, Measurement of low-frequency magnetic and electric fields with regard to exposure of human beings – Special requirements for instruments and guidance for measurements

